

Special Meeting
August 6, 1990

Council members present: Sanderson, Schiebel, Reece, King, Lutes
Also present: Gary Moler & Linda Waugh

The meeting was called to order by Mayor Gearhart at 7:00 P.M. for the purpose of looking at some problem areas of city property.

The group left the council chambers to inspect storm sewer inlet boxes, the south lift station, a ditch along Jennings in the mobile home park, the maintenance shed and the sewer plant.


The following needs to be done:

- Repair four storm sewer inlet boxes on Main & Grundy, Main St. north of the Co-op, Washington & Center and Center & Lincoln.
- The discharge line at the south lift station needs to be redesigned, the electrical box put on the wall on the outside of the building and the alarm light raised.
- Install line and several beehives in the ditch on the north side of Jennings in the mobile home park.
- The roof on the trickling filter needs to be repaired.
- A concrete floor should be poured in the maintenance building. Also a wall between stalls, floor drain, insulation and new lighting.
- The ditch south of Well #3 needs to be filled and used for city dumping of concrete and street sweepings.
- The force main from the south lift station should be rerouted.

The council returned to the city hall and a discussion followed.

Motion to adjourn by Reece, second by Sanderson. Carried.


Bill Gearhart, Mayor

Attest: 
Carol Whipple, Clerk